



Report Date: Tuesday, March 10, 2020

Page 1 of 2

Work Order#	843620315	Activity: WVON	REPLACE VALVE OPERATING NUT	
Address:	W 30 ST		Pct: 014	Zip: 10001
Cross Street:	7 AVE			
Compass Direction:			Borough: MANHATTAN	
Building ID:	0	Block:	Lot:	CMBD: 105
Water Valve ID:	V103330			
Qualifier:				Map# H27
Area:	1		Sub-Area: 105 MANHATTAN COMMUNITY BOARD 5	
Location :			District: 843620315	
Initiated By:	2333	DELLECAVE, ERIC	Initiated: 05-03-2017 07:36 AM	Scheduled: N/A
Assigned To:			Service# N/A	Due: N/A
Authorization:				
Crew:	W3	WATER - 3 LABORERS		
Maint Type:				
Priority:				
Problem:				Permit#
Project:				Completed: 05-03-2017 10:00 PM
Source:				Out of Service: N
Result:				Potential Service Request: N
WO Responsibility:	WRM	MANHATTAN REPAIRS		
WO Comments:	NORTH OF NORTH CURB LNE ON W 30 ST E/O/W CURB LNE OF 7TH AVE 12" M/L/G OP NUT NEEDS TO BE CHANGED. M/L/G IS DEEP AND WATER MAINTENANCE UNABLE TO CHANGE. OPERATING NUT CURRENTLY IN DOWN POSITION			
Work Order Log History				
Log Type	Log Started	Log Ended	Log By	Comments
INITIAL	05-03-2017	05-03-2017	12074- POPOVIC, ADMIR	SWUPERVISOR, POPVIC, CREW, MERCADO, BERILLIO, AND AGIULAR, SET UP SAFETY ZONE, EXCAVATED ARUND M/L/G, REMOVED O-NUT, PUT NEW O-NUT ON VALVE, OPENED 12" GATE, ALSO PACKED 12" GATE DUE TO PACKING LEAK, RESET M/L/G TO GRADE, B/F, B/T TAMPERED TO GRADE.. Input By: CATHERINE N BROWN on 5/8/2017 1:02:42 PM

There are no user logs for this work order

Activity Safety Messages: There are no Safety Messages for this asset's Activity Code

Asset Safety Messages: There are no Safety Messages for this asset

NYC0330